




K.R.E. Society's

R.V BIDAP LAW COLLEGE BIDAR

(Approved by BCI Delhi & Permanently Affiliated to Karnataka State Law University, Hubballi)

MANHALLI ROAD, BIDAR - 585 403. (KARNATAKA STATE) INDIA



2021-2023

Shweta Patil
Smt Shweta Patil
Dept. of Renewable Energy
Bachelor of Vocation
KASCE Bidar
Renewable Energy

Geetika
Auditor
ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಧ್ಯಯನಾಧಿಕಾರಿ (ಸಿ)
ಇಂಧನ ಮತ್ತು ವಿದ್ಯುತ್ ವಿಭಾಗ
GESCO Office
ಗು.ವಿ.ಸ.ಕಂ.ನಿ. ಹುಮನಾಟಾಡ

ACKNOWLEDGEMENT

We the Auditors from the department of B.Voc. Renewable Energy, Karnatak Arts, Science and Commerce College, Bidar and GESCOM OFFICE, express our sincere gratitude to the management of Karnatak Law College, Bidar, for awarding us the assignment of Energy Audit of their campus for the Year: 2021-23

We are thankful to various Head of Departments & other Staff members for helping us during the field measurements


Smt Shweta Patil
Dept. of Renewable Energy
Bachelor of Vocation
KASCC Bidar
Renewable Energy


Auditor
ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಹಣಾಧಿಕಾರಿ (ಸಿ)
ಕೆ.ಎಂ.ಎಸ್.ಎಸ್.ಎಸ್. - ವಿಭಾಗ
GESCOM Office
ಗು.ವಿ.ಸ.ಕಂ.ನಿ. ಹುಮನಾಟಾಡ

EXECUTIVE SUMMARY

An energy audit was carried out at R V BIDAP Law College to assess the current energy consumption and identify opportunities for reducing energy use. The audit covered various areas of the campus, including classrooms, offices, and common areas, with a focus on lighting, ventilation, and office equipment.

1. Present Energy Consumption:

No	Parameter /Value	Electrical Energy Consumed, kWh	CO2 Emissions, MT
1	Total	2680	2.412
2	Maximum	286	0.257
3	Minimum	190	0.171
4	Average	238	0.214

2. Various Majors Adopted for Energy Conservation:

- Usage of Energy efficient LED fittings
- Usage of BEE STAR Rated Equipment
- Maximum usage of Day Lighting

3. Notes : 1 kWh of Electrical Energy releases 0.9 Kg of CO₂ into atmosphere


Smt Shweta Patil
Dept. of Renewable Energy
KASCE Bidar
Bachelor of Vocation
Renewable Energy


Auditor
ಸಹಾಯಕ ಕಾರ್ಯನಿರೀಕ್ಷಕ ಅಭಿಯಂತರರು (ಸ)
ಇಂಧನ ಶೇಖರಣೆ ಮತ್ತು ವಿತರಣೆ ವಿಭಾಗ
GESCOM Office
ಗು.ವಿ.ಸ.ಕಂ.ನಿ. ಹುಮನಾಟಾದ

ABBREVIATIONS

CFL : Compact Fluorescent Lamp

FTL : Fluorescent Tube Light

LED : Light Emitting Diode

kWh : kilo-Watt Hour

Qty : Quantity

W : Watt

kW : Kilo Watt

PC : Personal Computer

MT : Metric Ton


Smt Shweta Patil
Dept. of Renewable Energy
KASCE Auditor
Bachelor of Vocation
Renewable Energy


Auditor
ಸಹಾಯಕ ಕಾರ್ಯನಿರೀಕ್ಷಕ ಅಭಿಯಂತರರು (ಸಿ)
GESCOT Office - ವಿಭಾಗ
ಗು.ವಿ.ಸ.ಕಂ.ನಿ. ಹುಮನಾಟಾಡ

CHAPTER-I

INTRODUCTION

An energy audit was conducted at R V BIDAP Law College to assess the current energy consumption patterns and identify potential areas for energy savings. The audit focused on the various electrical installations within the college, including lighting, fans, and office equipment. The data collected includes the number and types of lights, ceiling fans, computers, printers, and other electronic devices used in different locations across the college.

Objectives

The primary objectives of the energy audit were to:

1. Identify areas of excessive energy consumption.
2. Recommend measures to improve energy efficiency.
3. Promote sustainable energy practices within the campus
4. To study the present CO₂ emission
5. To study LED Lighting.

Table No1: General Details of College:

No	Head	Particulars
1	Name of Institution	Karnatak Law College, Bidar
2	Address	
3	Affiliation	


Smt Shweta Patil
Director of Renewable Energy
KASCE Bidar
Bachelor of Vocation
Renewable Energy


Auditor
ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಹಣಾಧಿಕಾರಿ (ಸಿ)
ಕೆ.ಎಂ.ಪಿ.ಎಸ್. - ವಿಭಾಗ
GESCOM Office
ಗು.ವಿ.ಸ.ಕಂ.ನಿ. ಹುಮನಾಟಾಡ

CHAPTER-II

STUDY OF CONNECTED LOAD

In this chapter, we present the details of various Electrical loads as under

Table No 2: Details of Equipment Wise Connected Load:

Sl.No.	Equipments	Quantity	Load W/Unit	Load in kW
1	40W FTL	25	40	0.100
2	20W LED	05	20	0.010
3	20W CFL	04	20	0.080
4	Ceiling fans	24	6	0.144
5	PC	19	150	2.850
6	Scanner	01	175	0.175
7	Projector	01	350	0.350
8	Other Load	15	150	2.250
	Total			5.959


Smt Shweta Patil
Director of Renewable Energy
KASCE Auditor
Bachelor of Vocation
Renewable Energy


Auditor
ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಹಣಾಧಿಕಾರಿ (ಸಿ)
GESCOT Office - ವಿಭಾಗ
ಗು.ವಿ.ಸ.ಕಂ.ನಿ. ಹುಮನಾಟಾಡ

CHAPTER-III

STUDY OF Present Energy CONSUMPTION

In this chapter, we present the analysis of last year Electricity Energy Consumption

Table No 3: Electrical Energy Consumption Analysis- 2023-24:

No	Month	Total Energy Consumed, kWh
1	May	190
2	June	210
3	July	222
4	August	195
5	September	198
6	October	234
7	November	201
8	December	228
9	January	286
10	February	262
11	March	212
12	April	242
	Total	2680


Smt Shweta Patil
Director of Renewable Energy
KASCE Auditor


Auditor
ಸಹಾಯಕ ಕಾರ್ಯನಿರೀಕ್ಷಕ ಅಭಿಯಂತರರು (ಸಿ)
GESCOT Office - ವಿಭಾಗ
ಗು.ವಿ.ಸ.ಕಂ.ನಿ. ಹುಮನಾಟಾಡ




Table No. 4 Variations in Important Parameters

No.	Parameters/Variation	Energy Purchased kW
1	Total	2680
2	Maximum	286
3	Minimum	190
4	Average	238


Smt Shweta Patil
 Director, Renewable Energy
 KASCE, Bidar
 Bachelor of Vocation
 Renewable Energy


Auditor
 ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಹಣಾಧಿಕಾರಿ (ಸಿ)
 ಗ್ರಾಂ.ವಿ.ಸಂ.ನಿ. ಕುಮನಾಟಾಡ
GESCOM Office

CHAPTER-IV

CARBON FOOTPRINTING

A Carbon Foot print is defined as the Total Greenhouse Gas emissions, emitted due to various activities.

In this we compute the emissions of Carbon-Di-Oxide, by usage of the various forms of Energy used by the College for performing its day to day activities. The College uses Electrical Energy for various Electrical gadgets.

Basis for computation of CO₂ Emissions:

The basis of Calculation for CO₂ emissions due to Electrical Energy is 1 kWh of Electrical Energy releases 0.9 Kg of CO₂ into atmosphere

Based on the above Data we compute the CO₂ emissions which are being released in to the atmosphere by the College due to its Day to Day operations

Table No 5: Month wise CO₂ Emissions:

No	Month	Total Energy Consumed, kWh	CO2 emissions, MT
1	May	190	0.171
2	June	210	0.189
3	July	222	0.199
4	August	195	0.175
5	September	198	0.178
6	October	234	0.210
7	November	201	0.180
8	December	228	0.205
9	January	286	0.257
10	February	262	0.238
11	March	212	0.190
12	April	242	0.217


Smt Shweta Patil
Director of Renewable Energy
KASCE Auditor
Bachelor of Vocation
Renewable Energy


Auditor
ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಹಣಾಧಿಕಾರಿ (ಸಿ)
GESCOM Office - ವಿಭಾಗ
ಗು.ವಿ.ಸ.ಕಂ.ನಿ. ಹುಮನಾಟಾಡ

13	Total	2680	2.412
14	Maximum	286	0.257
15	Minimum	190	0.171
16	Average	238	0.214




Table No. 6 : Important Parameters

No	Parameter /Value	Electrical Energy Consumed, kWh	CO2 Emissions, MT
1	Total	2991	2.691
2	Maximum	310	0.279
3	Minimum	212	0.190
4	Average	261	0.234


Smt Shweta Patil
 Director, Renewable Energy
 KASCE Auditor


Auditor
 ಸಹಾಯಕ ಕಾರ್ಯನಿರೀಕ್ಷಕ ಅಭಿಯಂತರರು (ಸಿ)
 ಗು.ವಿ.ಸ.ಕಂ.ನಿ. ಕುಮನಾಟಾಡ
GESCOM Office

Study of Connected Load
Location Wise Connected Load

Sl.No.	Location	No. of Florescent lamp (Tube Lights)	No of CFL's (watt)	No of LED's (watt)	No. of Ceiling Fan's	No. of PC's	No. of Printers
01	G6	02			01		
02	G7	02			02		
03	G8	02			01	01 projector	
04	G5	01			01		
05	G4	02			01	02	01scanner
06	G3	01			01	01	
07	G2	02		02	02		
08	G1	-	02		02		
01	F10	03	02		01	02	
02	F9	02			02	14	
03	F7	02		03	02		
04	F1	02			02		
01	S4	01			02		
02	S6	02			02		
03	S7	01			02		
	Total	25	04	05	24	19pc+01 proj.	01 scanner


Smt Shweta Patil
 Deputy Commissioner
 KASCE, Bidar
 Department of Renewable Energy
 Bachelor of Vocation
 Renewable Energy


Auditor
 ಸಹಾಯಕ ಕಾರ್ಯನಿರೀಕ್ಷಕ ಅಭಿಯಂತರರು (ಸಿ)
 ಗುಂಪು ಕಾರ್ಯನಿರೀಕ್ಷಕರು - ವಿಭಾಗ
GESCOM Office
 ಗು.ವಿ.ಸ.ಕಂ.ನಿ. ಹುಮನಾಟಾಡ

Recommendations:

- 1. LED Lighting:** Replace all fluorescent lamps and CFLs with LED lights, which are more energy-efficient and have a longer lifespan.
- 2. Energy-Efficient Ceiling Fans:** Consider replacing existing ceiling fans with energy-efficient models.
- 3. Optimize Ventilation Systems:** Regular maintenance and potential replacement of old fans with energy-efficient models can improve energy efficiency.
- 4. Optimize Computing Equipment:** Ensure that PCs and printers are turned off when not in use to avoid standby power consumption.

Conclusion

The energy audit conducted at R V BIDAP Law College revealed significant opportunities for enhancing energy efficiency across the campus. The audit highlighted key areas where energy consumption could be reduced through targeted interventions. By implementing the recommended measures, the college can achieve greater energy efficiency, leading to cost savings and a reduced environmental impact.


Smt Shweta Patil
Dept. of Renewable Energy
KASCE Bidar
Bachelor of Vocation
Renewable Energy


Auditor
ಸಹಾಯಕ ಕಾರ್ಯನಿರೀಕ್ಷಕ ಅಭಿಯಂತರರು (ಸಿ)
GESCOT Office - ವಿಭಾಗ
ಗು.ವಿ.ಸ.ಕಂ.ನಿ. ಹುಮನಾಟಾದ